

Hospital Safety Index



Washington DC, 2008
© Pan American Health Organization

A method for qualitative assessment of safety risks in health infrastructure exposed to natural and human-made hazards

**Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant**

OBSERVATIONS DURING FIELD TRIP TO LAAMU AND THAA ATTOLS



New Regional Hospital at Laamu Atoll – Ground Floor at Road Level

**Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant**

OBSERVATIONS DURING FIELD TRIP TO LAAMU AND THAA ATTOLS



New Regional Hospital at Laamu Atoll – Fire and Emergency Lighting Systems

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

Form 1

General Information About the Health Facility



The aim is to collect basic information such as:

- Population served
- Services available
- Area of influence
- Personnel available
- Physical distribution of services and buildings
- Key architectural plans, sketches, drawings, etc.

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

Form 2

Safe Hospitals Checklist

Elements relating to the geographic location.....	(MNBC-2010 Hazard Maps and Specs)	13
Elements related to the structural safety of the facility.....	(Maintenance Engineer)	16
Elements related to non-structural safety.....	(Maintenance Engineer)	18
Functional capacity of the hospital	(Hospital Administrator)	26

**Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant**

An example of Questionnaire Part 2 for Indira Gandhi Memorial Hospital (IGMH)

**Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant**

Observations on Structural Safety at IGMH



IGMH – Strong columns at basement

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

1. Elements relating to the GEOGRAPHIC LOCATION of the health facility (mark with an X where applicable).

1.1 Hazards Refer to hazard maps. Request the Hospital Disaster Committee to provide the maps showing safety hazards at the site of the building.	Hazard Level				OBSERVATIONS
	No hazard	Low	Medium	High	
1.1.1 Geological phenomena					
Earthquakes Rate the hazard level of the hospital in terms of geotechnical soil analyses.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Volcanic eruptions Refer to hazard maps of the region to rate the hospital's exposure to hazard in terms of its proximity to volcanoes, volcanic activity, routes of lava flow, pyroclastic flow, and ash-fall.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Landslides Refer to hazard maps to rate the level of hazard for the hospital in terms of landslides caused by unstable soils (among other cause).	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Currently not considered as a threat.
Tsunami Refer to hazard maps to rate the level of hazard for the hospital in terms of previous tsunami events caused by submarine seismic or volcanic activity.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	IN 2004, THE TSUNAMI'S DIRECT IMPACT WAS TO EASTERN SIDE OF MALDIVES. THIS IS THE FIRST EVENT OF SUCH NATURE RECORDED IN HISTORY OF MALDIVES.
Others (specify) Refer to hazard maps to identify other geological phenomena not listed above. Specify the hazard and rate the corresponding hazard level for the hospital.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
1.1.2 Hydro-meteorological phenomena					
Hurricanes Refer to hazard maps to rate the hazard level of the hospital in terms of hurricanes. It is helpful to take into account the history of such events when rating the hazard level of the facility.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Torrential rains Rate the hazard level for the hospital in relation to flooding due to intensive rainfall, based on the history of such events.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Storm surge or river flooding Rate the hospital's level of exposure to storm surge or river flooding hazards based on previous events that did or did not cause flooding in or around the hospital.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Landslides Refer to geological maps to rate the hospital's level of exposure to landslides hazards caused by saturated soil.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Others (specify) SEA SWELLING AND SEA LEVEL RISE Refer to hazard maps to identify other hydro-meteorological hazards not listed above. Specify the hazard and rate the corresponding hazard level for the hospital.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	IGMH GROUND FLOOR IS LOCATED AT 2 M ABOVE SEA LEVEL BUT THE BASEMENT IS AT OR BELOW SEA LEVEL. THE NATURAL GLOBAL PHENOMENON OF SEA LEVEL RISE IS CONSIDERED TO AGGRAVATE THE EFFECTS OF SEA SWELLING DURING STORM SURGES CAUSED BY TROPICAL CYCLONES OR LOW PRESSURE SYSTEMS.

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

MNBC-2010 COMPLIANCE DOCUMENTS Earthquake Design Parameters and Hazard Chart

B Stability

B1 Structure




Table I.4.2 Zone Factors (Z) for Building Design in Earthquake Hazard Zones

Zone Factors ($Z = PGA/g$); $g = 9.81 \text{ m/s}^2$ (gravity acceleration)		
ZONE	T = 475 years, for life safety design using IS 1893 (Part I)**	T = 50 years, for Property Loss Protection*
1	0.10	0.02
2	0.16	0.03

*Best estimate – not computed

** Revised from values computed in UNDP – RMSI (2006) study for T = 475 years

EARTHQUAKE HAZARD RISK	
HAZARD ZONE	RISK LEVEL
1	Low
2	Moderate

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

UNDP – RMSI 2006 ASSESSMENT MNBC –2010 REVIEW

Table A.9 Return Periods for Maximum Tsunami Wave Height (TWH) greater than 0.5 meters in Maldives Islands by UNDP-RMSI (2006)

Earthquake Recurrence	Probability of Exceedance in 50 years PE(50)	Annual Probability of Occurrence N(M)	Return Period T (years)	Earthquake Moment Magnitude Mw	Maximum Tsunami Wave Height (m)
Rare	10%	0.00211	475	8.5	0.5
Very Rare	2%	0.000404	2475	9.0	4.5

$[\text{Log}N(M) = a - bM], [T(\text{years}) = 1/N(M)] \text{ and } [PE(t \text{ years}) = 1 - \exp[-N(M)*t]]$




Figure A.10 The Tsunami Hazard Zones in Maldives by UNDP-RMSI (2006)

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

Site Assessment for Tsunami Hazard

The following conditions shall be considered:

- Tide elevation during previous tsunamis
- Proximity to shore
- Ground floor elevation
- Sacrificial Fences

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

MNBC-2010 COMPLIANCE DOCUMENTS Wind Design Parameters and Hazard Chart

B Stability


B1 Structure

Table I.4.1 Sustained Wind Speeds for Building Design in Wind Hazard Zones

ZONE	SUSTAINED WIND SPEEDS			
	T = 50 years, V _b ** for life safety design using BS 6399-2		T = 25 years, for Property Loss Protection*	
	KM/H	m/s	KM/H	m/s
4	140	39	80	22
3	120	33	70	19
2	100	28	60	17
1	80	22	50	14

*Best estimate – not computed

** Adapted from values computed in UNDP – RMSI (2006) study for gusty winds with T = 500years



WIND HAZARD RISK	
HAZARD ZONE	RISK LEVEL
1	Very Low
2	Low
3	Moderate
4	High

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

1.2 Geotechnical properties of soils				
Liquefaction With reference to the geotechnical soil analysis at the hospital site, rate the level of the facility's exposure to hazards from saturated and loose subsoil.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Clay soils With reference to soil maps, rate the hospital's exposure to hazards from clay soil.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Unstable slopes Refer to geological maps and specify the hospital's exposure to hazards from the presence of slopes.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Comments on the results of Form 2, Module 1. The evaluator should use the space below to comment on the results of this module (1), and provide his/her name and signature.

Hospital Liquid Waste System - No treatment is provided and waste is discharged to Island Sewage System, which discharge to Sea close to hospital premises (< 300 m distance)

Hospital uses Potable Water from Male Desalination Water Plant - Desalinated water is collected through a bore hole 40 metres deep.

Water from a well is used for toilets and non-potable usage.

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives, Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

2. Elements related to the structural safety of the building

Columns, beams, walls, floor slabs, etc., are structural elements that form part of the load-bearing system of the building. These elements should be evaluated by structural engineers.

2.1 Prior events affecting hospital safety	Safety level			OBSERVATIONS
	LOW	AVERAGE	HIGH	
1. Has there been prior structural damage to the hospital as a result of natural phenomena? Determine whether structural reports indicate that the level of safety has been compromised. IF SUCH AN EVENT HAS NOT OCCURRED IN THE VICINITY OF THE HOSPITAL, LEAVE BOXES BLANK. Low = Major damage; Average = Moderate damage; High = Minor damage.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK (REMOVE MARK FROM BOX)
2. Was the hospital built and/or repaired using current safety standards? Verify whether the building has been repaired, the date of repairs, and whether repairs were carried out using standards for safe buildings. Low = Current safety standards not applied; Average = Current safety standards partially applied; High = Current safety standards fully applied.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Currently working on a programme to determine the risk of a fire event within the hospital, and taking measures to reduce this.
3. Has remodelling or modification affected structural behavior of the facility? Verify whether modifications were carried out using standards for safe buildings. Low = Major remodelling or modifications have been carried out; Average = Moderate remodelling and/or modifications; High = Minor remodelling and/or modifications or no modifications were carried out.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	MODIFICATIONS HAVE NOT SIGNIFICANTLY AFFECTED STRUCTURAL SAFETY
2.2 Safety of the structural system and type of materials used in the building	Safety level			OBSERVATIONS
	LOW	AVERAGE	HIGH	
4. Condition of the building Low = Deterioration caused by weathering; cracks on the first floor and irregular height of building; Average = Deterioration caused only by weathering; High = Good; no deterioration or cracks observed.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5. Construction materials used Low = Rust with flaking; cracks larger than 3mm; Average = Cracks between 1 and 3 mm or rust powder present; High = Cracks less than 1 mm; no rust.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6. Interaction of non-structural elements with the structure Low = Separation of less than 0.5% of the height of the partition/joint; Average = Separation between 0.5 and 1.5% of the height of the partition/joint; High = Separation above 1.5% of the partition/joint.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
7. Proximity of buildings (hazards of pounding, wind tunnel effects, fires, etc.) Low = Separation is less than 0.5% of the height of the shorter of two adjacent buildings; Average = Separation is between 0.5% and 1.5% of the height of the shorter of two adjacent buildings; High = Separation is more than 1.5% of the height of the shorter of two adjacent buildings.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
8. Structural redundancy Low = Fewer than three lines of resistance in each direction; Average = Three lines of resistance in each direction or lines without orthogonal orientation; High = More than three lines of resistance in each orthogonal direction of the building.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives, Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

<p>9. Structural detailing, including connections Low = Built before 1970; Average = Built between 1970 and 1990; High = Built after 1990 and according to standards.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
<p>10. Safety of foundations Low = Information is lacking or foundation depth is less than 1.5 m; Average = Plans and soil studies are lacking but foundation depth is more than 1.5 m; High = Plans, soil studies are available and foundation depth is more than 1.5 m.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SOIL CONDITIONS ARE KNOWN FOR MALE ISLAND
<p>11. Irregularities in the plan (rigidity, mass, and resistance) Low = Shapes are irregular and structure is not uniform; Average = Shapes are irregular but structure is uniform; High = Shapes are regular, structure has uniform plan, and there are no elements that would cause torsion.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
<p>12. Irregularities in height (rigidity, mass, and resistance) Low = Height of storeys differs by more than 20% and there are significant discontinuous or irregular elements; Average = Storeys have similar heights (they differ by less than 20% but more than 5%) and there are few discontinuous or irregular elements; High = Storeys of similar height (they differ by less than 5%); there are no discontinuous or irregular elements.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
<p>13. Structural resilience to various phenomena (meteorological, geological, among others) Estimate structural behavior in response to different hazards or dangers, other than earthquakes. Low = Low structural resilience to natural hazards present at the site of the hospital; Average = Satisfactory structural resilience; High = Excellent structural resilience.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	A CONCERN COULD BE RAISED ON THE DURABILITY OF REINFORCEMENT DUE TO CORROSION ACTIVITY. NOT YET SIGNIFICANT CORROSION ACTIVITY IS OBSERVED AFTER 15 YEARS OF SERVICE

Comments on the results of Form 2, Module 2:

MANY QUESTIONS MAY BE ANSWERED AS FOLLOWS:

"LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE"

THE STRUCTURE IS EXPOSED TO THE EFFECTS OF SERVICE GRAVITY LOADS, FLOODS AND FIRES, THUS SOME OF THE QUESTIONS COULD BE ANSWERED ACCORDINGLY (LOW, MODERATE OR HIGH) DEPENDING ON

HOW THE VULNERABILITY FACTOR UNDER CONSIDERATION COULD AFFECTED STRUCTURE STABILITY AND DURABILITY TO SERVICE GRAVITY LOADS AND THE PREVAILING NATURAL AND MAN-MADE HAZARDS.

EXCEPTIONS: HOSPITALS IN THE UPMOST NORTH ATOLLS ARE EXPOSED TO HIGH WIND HAZARD AND IN THE UPMOST SOUTH ARE EXPOSED TO MODERATE SEISMIC EVENTS. SEE HAZARD MAPS FROM THE MALDIVIAN BUILDING CODE REVIEW PROJECT 2010 (UNDP-MHTE PROJECT).

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives, Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

Observations on Non-Structural Safety at IGMH



IGMH – Narrow Corridors, Fire System need rehab and Inadequate Means of Egress (No signs and open doors)

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives, Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

3. Elements related to non-structural safety

Non-structural elements do not form part of the load-bearing system of the building. They include architectural components, equipment, and systems that are necessary for the operation of the building.

3.1 Critical systems	Safety level			OBSERVATIONS
	LOW	AVERAGE	HIGH	
3.1.1 Electrical system				
<p>14. Generator has capacity to meet 100% of demand Verify that the generator begins to operate within seconds of the hospital losing power, covering power demands for the entire hospital, particularly in the emergency department, intensive care unit, sterilization unit, operating theatres, etc. <i>Low = Generator can only be started manually or covers 0-50% of demand; Average = Generator starts automatically in more than 10 seconds or covers 51%-70% of demand; High = Generator starts automatically in less than 10 seconds and covers 71%-100% of demand.</i></p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Generator capacity is of 1MegaKV, which can provide 5% of the requirement of the hospital.
<p>15. Regular tests of generator performance are carried out in critical areas Determine the frequency of generator performance tests that have satisfactory results. <i>Low = Tested every 3 months or more; Average = Tested every 1 to 3 months; High = Tested at least monthly.</i></p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tested every week.
<p>16. Generator protected from damage due to natural phenomena <i>Low = No; Average = Partially; High = Yes.</i></p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3 GENERATORS - 2 GENERATORS NOT OPERATIONAL (leaking from the diesel connections)
<p>17. Safety of electrical equipment, cables, and cable ducts <i>Low = No; Average = Partially; High = Yes.</i></p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	electrical wiring and water piping at basement are running together and the fire water system is broken
<p>18. Redundant system for local electric power supply <i>Low = No; Average = Partially; High = Yes.</i></p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<p>19. Protection for control panel, overload breaker switch, and cables Check the accessibility as well as condition and operation of the central electrical control panel. <i>Low = No; Average = Partially; High = Yes.</i></p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<p>20. Lighting system for critical areas of the hospital Review lighting for emergency unit, intensive care unit, operating theatres, etc, testing the level of lighting in rooms and function of lighting fixtures. <i>Low = No; Average = Partially; High = Yes.</i></p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Checked only when a problem is encountered.
<p>21. External electrical systems installed on hospital grounds Verify the existence and capacity of external substations that provide power to the hospital. <i>Low = No electrical substations installed on hospital's grounds; Average = Substations installed but do not provide enough power to hospital; High = Electrical substations installed and provide enough power to the hospital.</i></p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Provided by Electrical Company of Male' (STELCO) Not a reliable supply

**Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant**

3.1.2 Telecommunications system				
<p>22. Condition of antennas and antenna bracing Verify the condition of antennas and their bracing/supports. <i>Low = Poor or does not exist; Average = Satisfactory; High = Good.</i></p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
<p>23. Condition of low-voltage systems (Internet and telephone connections/cables) Verify that cables are properly connected in strategic areas to avoid system overload. <i>Low = Poor or does not exist; Average = Satisfactory; High = Good.</i></p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
<p>24. Condition of alternative communications systems Verify the condition of other communications systems: radio communications, satellite telephone, Internet, etc. <i>Low = Poor or does not exist; Average = Satisfactory; High = Good.</i></p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
<p>25. Condition of anchors and braces for telecommunications equipment and cables Verify that telecommunications equipment (radics, satellite telephone, video conferencing system, etc.) is anchored for increased security. IF THE SYSTEM DOES NOT NEED ANCHORS OR BRACING, LEAVE BOXES BLANK. <i>Low = Poor; Average = Satisfactory; High = Good.</i></p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
<p>26. Condition of external telecommunications systems installed on hospital grounds Verify that external telecommunications systems do not interfere with communications of the hospital. <i>Low = External telecommunications systems cause major interference with hospital communications; Average = External telecommunications systems cause moderate interference with hospital communications; High = External communications cause no interference with hospital communications.</i></p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
<p>27. Site has adequate conditions for telecommunications systems <i>Low = Poor or does not exist; Average = Satisfactory; High = Good.</i></p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	BUT IN CASE OF A SYSTEM FAILURE NO OTHER METHOD OF COMMUNICATION.
<p>28. Safety of internal communications systems Verify the condition of loudspeakers, public address system, speaker systems, etc. <i>Low = Poor or does not exist; Average = Satisfactory; High = Good.</i></p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
3.1.3 Water supply system				
<p>29. Water tank has permanent reserve that is sufficient to provide at least 300 liters daily, per bed, for 72 hours Verify that water storage is sufficient to satisfy user demand for three days. <i>Low = Sufficient for 24 hours or less; Average = Sufficient for more than 24 hours but less than 72 hours; High = Guaranteed to cover at least 72 hours.</i></p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	WATER TANK *1 SALT WATER / 1 FRESH WATER (USED FOR TOILET FLUSHING) *2 TANKS - 550 M ³ (65,000 LITRES) - RAIN WATER (ONLY FOR WASHING PUPODED) * DAILY REQUIRED = 132000 LITRES. Currently no water reserve.
<p>30. Water storage tanks are protected and in secure locations Visit the water tanks to determine the safety of the installations and of the site. <i>Low = The site is susceptible to structural or non-structural failure; Average = Failure would not cause collapse of tank; High = Low possibility of functional failure.</i></p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	LEAKING IN 1 TANK. MAINTAINANCE FOR THE OTHER THREE TANKS TO WORK.

**Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
Jaime F. Argudo, Ph.D., P.E. – WHO Consultant**

<p>31. Alternative water supply to major distribution network Identify the agency or mechanism to supply or restore water service to the hospital should the public water system fail. Low = Provides less than 30% of demand; Average = Provides 30% to 80% of demand; High = Provides more than 80% of daily demand.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water supply is through the State Water Supply Company. No other alternative at present.
<p>32. Condition of water distribution system Verify condition and proper performance of water distribution system, including storage tanks, valves, pipes, and connections. Low = Less than 60% are in good operational condition; Average = Between 60% and 80% are in good condition; High = Above 80% are in good condition.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	90% of pipes renovated recently.
<p>33. Supplementary pumping system Identify the existence and operation of the supplementary pumping system in case water supply is interrupted. Low = There is no back-up pump and operational capacity does not meet daily demand; Average = All pumps are in satisfactory condition; High = All pumps and back-up systems are operational.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2 pumps, not in good condition.
3.1.4 Fuel storage (gas, gasoline, diesel)				
<p>34. Fuel tanks have at least 5-day capacity Verify that the hospital has fuel storage tanks of adequate size and safety. Low = Fuel storage is not secured and has less than 3-day fuel capacity; Average = Fuel storage has some security and has 3-5 days fuel capacity; High = Fuel storage is secure and has capacity for 5 or more days.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1 FUEL TANK 4000 LITRES - DIESEL - Gives for 7 days approximately. NOT LOCATED IS A SAFE PLACE
<p>35. Fuel tanks and/or cylinders are anchored and in a secure location Low = There are no anchors and the tank enclosure is unsafe; Average = Anchors are inadequate; High = Anchors are in good condition and the tank enclosure is adequate.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
<p>36. Safe location of fuel storage Verify that the tanks containing combustible liquids are accessible but at a safe distance from the hospital. Low = There is risk of failure and that tanks are not accessible; Average = One of the two conditions have been met; High = The fuel storage tanks are accessible and they are located in a secure site.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4-6 FEET FROM NICU. NOT EASY to access by fire fighting means
<p>37. Safety of the fuel distribution system (valves, hoses, and connections) Low = Less than 60% of system is in good operational condition; Average = between 60% and 80% of system is in good operational condition; High = More than 80% of system is in good operational condition.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Leaking from tanks, malfunctioning valves.
3.1.5 Medical gases (oxygen, nitrogen, etc.)				
<p>38. Sufficient medical gas storage for minimum of 15-day supply Low = Less than 10-day supply; Average = Supply for between 10 and 15 days; High = Supply for at least 15 days.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	DAILY Requirement - 15-18 CYLINDERS. Delivery is every other day 25 cylinders. Currently with no back-up.
<p>39. Anchors for medical gas tanks, cylinders, and related equipment Low = Anchors are lacking; Average = Quality of anchors is inadequate; High = Anchors are of good quality.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
<p>40. Availability of alternative sources of medical gases Low = Alternative sources are lacking or are below standard; Average = Alternative sources exist and are in satisfactory condition; High = Alternative sources exist and are in good condition.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Currently working on a plan to verify this problem.
<p>41. Appropriate location for storage of medical gases Low = Storage is not accessible; Average = Storage is accessible but hazards exist; High = Storage is accessible and there are no hazards.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	NOT EASY to access by fire fighting means No reliable system for medical gases

<p>42. Safety of medical gas distribution system (valves, pipes, connections) Low = Less than 60% of system is in good working condition; Average = Between 60% and 80% of system is in good working condition; High = More than 80% of system is in good working condition.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
<p>43. Protection of medical gas tanks and/or cylinders and related equipment Low = No areas are used exclusively for this equipment and there are no qualified personnel to operate it; Average = Areas are used exclusively for this equipment but personnel are not trained to operate it; High = There are areas used exclusively for this equipment and it is operated by qualified personnel.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
<p>44. Adequate safety in storage areas Low = No areas are reserved for storage of medical gases; Average = Areas are reserved for storage of medical gases but safety measures are inadequate; High = There are areas reserved for storage of medical gases and the site does not present risks.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
3.2 Heating, ventilation, and air-conditioning (HVAC) systems in critical areas				Safety level	OBSERVATIONS
				LOW AVERAGE HIGH	
<p>45. Adequate supports for ducts and review of flexibility of ducts and piping that cross expansion joints Low = Supports are lacking and connections are rigid; Average = Supports are present or connections are flexible; High = Supports are present and connections are flexible.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
<p>46. Condition of pipes, connections, and valves Low = Poor; Average = Satisfactory; High = Good.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		Hospital central AC system is not working.
<p>47. Condition of anchors for heating and/or hot water equipment Low = Poor; Average = Satisfactory; High = Good.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
<p>48. Condition of anchors for air-conditioning equipment Low = Poor; Average = Satisfactory; High = Good.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
<p>49. Location of enclosures for HVAC equipment Low = Poor; Average = Satisfactory; High = Good.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		BASEMENT ACs - OUTLINE IS TOWARDS INSIDE THE HOSPITAL.
<p>50. Safety of enclosures for HVAC equipment Low = Poor; Average = Satisfactory; High = Good.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
<p>51. Operating condition of HVAC equipment (boiler, air-conditioning systems, exhaust, etc.) Low = Poor; Average = Satisfactory; High = Good.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4 EXHAUST - NOT WORKING.
3.3 Office and storeroom furnishings and equipment (fixed and movable) including computers, printers, etc.				Safety level	OBSERVATIONS
				LOW AVERAGE HIGH	
<p>52. Anchors for shelving and safety of shelf contents Verify that shelves are anchored to the walls and/or are braced and that contents are secured. Low = Shelving is not attached to walls; Average = Shelving is attached but contents are not secured; High = Shelving is attached and contents are secured.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
<p>53. Safety of computers and printers Verify that computer tables are anchored and table wheels are locked. Low = Poor; Average = Satisfactory; High = Good or does not require anchor.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE

54. Condition of office furnishings and other equipment Check anchors and/or bracing on furnishings in offices. <i>Low = Poor; Average = Satisfactory; High = Good or does not require anchor.</i>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
3.4 Medical and laboratory equipment and supplies used for diagnosis and treatment	Safety level			OBSERVATIONS
	LOW	AVERAGE	HIGH	
55. Medical equipment in operating theaters and recovery rooms Verify that lamps, equipment for anaesthesia, and surgical tables are operational and that table or cart wheels are locked. <i>Low = The equipment is in poor condition or it is not secured; Average = The equipment is in fair condition or not properly secured; High = Equipment is in good condition and is secured.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	answer in context of stability to impact by people
56. Condition and safety of radiology and imaging equipment Verify that the X-ray and imaging equipment is in good condition and is secured. <i>Low = The equipment is in poor condition or it is not secured; Average = The equipment is in fair condition or not properly secured; High = Equipment is in good condition and is secured.</i>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
57. Condition and safety of laboratory equipment <i>Low = The equipment is in poor condition or it is not secured; Average = The equipment is in fair condition or not properly secured; High = Equipment is in good condition and is secured.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	answer in context of stability to impact by people
58. Condition and safety of medical equipment in emergency services unit <i>Low = The equipment is in poor condition or it is not secured; Average = The equipment is in fair condition or not properly secured; High = Equipment is in good condition and is secured.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	answer in context of stability to impact by people
59. Condition and safety of medical equipment in intensive or intermediate care unit <i>Low = The equipment is in poor condition or it is not secured; Average = The equipment is in fair condition or not properly secured; High = Equipment is in good condition and is secured.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	answer in context of stability to impact by people
60. Condition and safety of equipment and furnishings in the pharmacy <i>Low = The equipment is in poor condition or it is not secured; Average = The equipment is in fair condition or not properly secured; High = Equipment is in good condition and is secured.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	answer in context of fire
61. Condition and safety of equipment in the sterilization unit <i>Low = The equipment is in poor condition or it is not secured; Average = The equipment is in fair condition or not properly secured; High = Equipment is in good condition and is secured.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	answer in context of fire
62. Condition and safety of medical equipment for neonatal care <i>Low = The equipment is lacking, is in poor condition, or it is not secured; Average = The equipment is in fair condition or not properly secured; High = Equipment is in good condition and is secured.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	answer in context of stability to impact by people
63. Condition and safety of medical equipment and supplies for burn management <i>Low = The equipment is lacking, is in poor condition, or it is not secured; Average = The equipment is in fair condition or not properly secured; High = Equipment is in good condition and is secured.</i>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
64. Condition and safety of medical equipment for nuclear medicine and radiation therapy IF THE HOSPITAL DOES NOT HAVE THESE SERVICES, LEAVE BOXES BLANK. <i>Low = The equipment is lacking, is in poor condition, or it is not secured; Average = The equipment is in fair condition or not properly secured; High = Equipment is in good condition and is secured.</i>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	answer in context of stability to impact by people
65. Condition and safety of medical equipment in other services <i>Low = More than 30% of equipment is at risk of material or functional failure and/or equipment puts the entire services operation at direct or indirect risk; Average = Between 10% and 30% of equipment is at risk of loss; High = Less than 10% of equipment is at risk of loss.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	answer in context of fire answer in context of stability to impact by people

66. 66. Anchors for shelving and safety of medical contents <i>Low = Shelves are anchored or shelf contents are secured in less than 20% of cases; Average = Shelves are anchored or shelf contents are secured in 20% to 80% of cases; High = More than 80% of shelves are anchored and the contents of shelves are secured (or shelving and contents do not require anchors).</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	answer in context of stability to impact by people
3.5 Architectural elements	Safety level			OBSERVATIONS
	LOW	AVERAGE	HIGH	
67. Condition and safety of doors and entrances <i>Low = Subject to damage and damage to element(s) would impede the performance of this and other components, systems, or operations; Average = Subject to damage but damage to element(s) would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	60% - SOME AREAS OF DAMAGE - answer in context of fire
68. Condition and safety of windows and shutters <i>Low = Subject to damage and damage to element(s) would impede the performance of this and other components, systems, or operations; Average = Subject to damage but damage to element(s) would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	60% - SOME AREAS OF DAMAGE - answer in context of fire
69. Condition and safety of other elements of the building envelope (outside walls, facings, etc.) <i>Low = Subject to damage and damage to element(s) would impede the performance of this and other components, systems, or operations; Average = Subject to damage but damage to element(s) would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.</i>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
70. Condition and safety of roofing <i>Low = Subject to damage and damage to element(s) would impede the performance of this and other components, systems, or operations; Average = Subject to damage but damage to element(s) would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	answer in context of fire
71. Condition and safety of parapets (wall or railing placed to prevent falls on roofs, bridges, stairs, etc.) <i>Low = Subject to damage and damage to element(s) would impede the performance of this and other components, systems, or operations; Average = Subject to damage but damage to element(s) would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.</i>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
72. Condition and safety of perimeter walls and fencing <i>Low = Subject to damage and damage to element(s) would impede the performance of this and other components, systems, or operations; Average = Subject to damage but damage to element(s) would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.</i>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE
73. Condition and safety of other outside elements (cornices, ornaments, etc.) <i>Low = Element(s) subject to damage and damage would impede the performance of this and other components, systems, or operations; Average = Element(s) subject to damage but damage would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.</i>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	NON EXISTANT.

74. Safe conditions for movement outside of building Low = Damage to structure or road and walkways will impede access to buildings or endanger pedestrians; Average = Damage to structure or road and walkways will not impede pedestrian access, but will impede vehicle access; High = No or minor potential for slight damage which will impede pedestrian or vehicle access.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	AMBULANCE HAS THE SAME ROUTE AS THE OTHER VEHICLES - ENTRANCE SAME TO STAFF AND OTHERS. Answer in context of fire
75. Safe conditions for movement inside the building (corridors, stairs, elevators, exit doors, etc.) Low = Subject to damage and damage to element(s) will impede movement inside building and endanger occupants; Average = Damage to elements will not impede movement of people but will impede movement of stretchers, wheeled equipment; High = No or minor potential for slight damage which will not impede movement of people or wheeled equipment.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	* 2 ELEVATORS - PATIENTS + STAFF USE * 2 ELEVATORS - VISITORS ELEVATORS - ON AND OFF - PROBLEM *EMERGENCY EXIT - LOCKED AND KEYS KEPT WITH SECURITY.
76. Condition and safety of internal walls and partitions Low = Element(s) subject to damage and damage would impede the performance of this and other components, systems, or operations; Average = Element(s) subject to damage but damage would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	answer in context of fire
77. Condition and safety of false or suspended ceilings IF THE HOSPITAL DOES NOT HAVE FALSE OR SUSPENDED CEILINGS, LEAVE BOXES BLANK Low = Element(s) subject to damage and damage would impede the performance of this and other components, systems, or operations; Average = Element(s) subject to damage but damage would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	answer in context of fire
78. Condition and safety of internal and external lighting systems Low = Element(s) subject to damage and damage would impede the performance of this and other components, systems, or operations; Average = Element(s) subject to damage but damage would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	answer in context of fire
79. Condition and safety of fire protection system Low = Element(s) subject to damage and damage would impede the performance of this and other components, systems, or operations; Average = Element(s) subject to damage but damage would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	fire system is not operational
80. Condition and safety of elevator system IF THERE ARE NO ELEVATORS, LEAVE BOXES BLANK. Low = Element(s) subject to damage and damage would impede the performance of this and other components, systems, or operations; Average = Element(s) subject to damage but damage would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	answer in context of fire
81. Condition and safety of stairways Low = Element(s) subject to damage and damage would impede the performance of this and other components, systems, or operations; Average = Element(s) subject to damage but damage would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	STAIRWAYS ARE USUALLY LOCKED.
82. Condition and safety of floor coverings Low = Element(s) subject to damage and damage would impede the performance of this and other components, systems, or operations; Average = Element(s) subject to damage but damage would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	answer in context of fire

83. Hospital access routes Low = Element(s) subject to damage and damage would impede the performance of this and other components, systems, or operations; Average = Element(s) subject to damage but damage would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	7 DOORS *3 CLOSED answer in context of fire
84. Other architectural elements, including emergency signs Low = Element(s) subject to damage and damage would impede the performance of this and other components, systems, or operations; Average = Element(s) subject to damage but damage would not impede function; High = No or minor potential for damage that would impede the performance of this and other components, systems, or operations.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	answer in context of fire

Comments on the results of Form 2, Module 3:

MANY QUESTIONS MAY BE ANSWERED AS FOLLOWS:

"LEAVE THIS BOX BLANK NO CONCERN ON MODERATE TO HIGH EARTHQUAKE OR WIND LOADS, THEREFORE THIS VULNERABILITY FACTOR IS NOT AN ISSUE"

THE STRUCTURE IS EXPOSED TO THE EFFECTS OF SERVICE GRAVITY LOADS, FLOODS AND FIRES, THUS SOME OF THE QUESTIONS COULD BE ANSWERED ACCORDINGLY (LOW, MODERATE OR HIGH) DEPENDING ON

HOW THE VULNERABILITY FACTOR UNDER CONSIDERATION COULD AFFECTED STRUCTURE STABILITY AND DURABILITY TO SERVICE GRAVITY LOADS AND THE PREVAILING NATURAL AND MAN-MADE HAZARDS.

EXCEPTIONS: HOSPITALS IN THE UPMOST NORTH ATOLLS ARE EXPOSED TO HIGH WIND HAZARD AND IN THE UPMOST SOUTH ARE EXPOSED TO MODERATE SEISMIC EVENTS. SEE HAZARD MAPS FROM THE MALDIVIAN BUILDING CODE REVIEW PROJECT 2010 (UNDP-MHTE PROJECT).

OBSERVATIONS DURING SITE VISIT TO INDIRA GANDHI MEMORIAL HOSPITAL AT MALE



IGMH – Fire system inoperative and Storage Areas at Basement

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives, Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

4. Safety based on functional capacity of hospital

The level of preparedness of hospital staff for major emergencies and disasters as well as the level of implementation of the hospital disaster plan.

4.1 Organization of the Hospital Disaster Committee and the Emergency Operations Center. Assess the level of organization achieved by the Hospital Disaster Committee.	Level of organization			OBSERVATIONS
	LOW	AVERAGE	HIGH	
85. Committee has been formally established to respond to major emergencies or disasters Obtain a copy of the Committee's terms of reference and verify that the list of members corresponds to current personnel. Low = Committee does not exist; Average = Committee exists but is not functioning; High = Committee exists and is functioning.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
86. Committee membership is multi-disciplinary Verify that the positions on the Committee are occupied by personnel from diverse disciplines (for example, hospital director, chief of nursing, maintenance engineer, head of emergency services, medical director, chief of surgery, chief of laboratory and support services, among others). Low = 0-3 disciplines represented; Average = 4-5 disciplines represented; High = 6 or more disciplines represented.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
87. Each member is aware of his/her specific responsibilities Verify that members' assigned responsibilities are in writing, describing their specific roles. Low = Responsibilities not assigned; Average = Responsibilities have been officially assigned; High = All members know and comply with their responsibilities.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
88. Space is designated for the hospital Emergency Operations Centre (EOC) Verify that a room has been designated for operational command and that all means of communication are present (telephone, fax, Internet, etc.). Low = Nonexistent; Average = Space has been officially assigned; High = EOC exists and is functional.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
89. The EOC is in a protected and safe location Take into account accessibility, safety, and protection when checking the room used for the EOC. Low = The room for the EOC is not in a safe location; Average = The EOC is in a safe location but it is not easily accessible; High = The EOC is in a safe, protected, and easily accessible location.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
90. The EOC has a computer system and computers Verify that the EOC has Internet and intranet connections. Low = No; Average = Incomplete; High = The EOC has all computer system requirements	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	No Committee See Question 85
91. Both internal and external communications systems in the EOC function properly Determine whether the switchboard (telephone central for re-routing calls) has a paging or a public address system and the operators know the emergency codes and how to use them. Low = Does not function or is nonexistent; Average = Partly functional; High = Complete and functional.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
92. The EOC has an alternative communications system Determine whether, besides the switchboard, there is an alternative communications system (e.g. cellular, two-way radio, etc.). Low = Nonexistent; Average = Incomplete; High = Yes.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
93. The EOC has adequate equipment and furnishings Verify that there are desks, chairs, power outlets, lighting, water supply, and drainage. Low = No; Average = Incomplete; High = Yes.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	No Committee See Question 85

94. An up-to-date telephone directory is available in the EOC Confirm that the directory includes all support services needed in an emergency (randomly check telephone numbers). Low = No; Average = Directory exists but is not up-to-date; High = Available and current.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
95. "Action Cards" available for all personnel Verify that action cards describe the assigned duties of each hospital staff member in case of an internal or external disaster. Low = No; Average = Insufficient (numbers and quality); High = All staff members have cards.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
4.2 Operational plan for internal or external disasters	Level of Implementation			OBSERVATIONS
	LOW	AVERAGE	HIGH	
96. Strengthen essential hospital services The plan specifies actions to be taken before, during, and after a disaster in the hospital's essential services (emergency room, intensive care unit, sterilization unit, operating theatre, among others). Low = Plan does not exist or exists only as a document; Average = Plan exists and personnel have been trained; High = Plan exists, personnel have been trained, and resources are in place to carry out the plan.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	PEOPLE TRAINED - PARTICIPATED IN WORKSHOP STAFF YEARLY WITH HIGH TURN OVER.
97. Procedures to activate and deactivate the plan Verify that there are procedures for how, when, and by whom the plan is activated/deactivated. Low = Plan does not exist or exists only as a document; Average = Plan exists and personnel have been trained; High = Plan exists, personnel have been trained, and resources are in place to carry out the procedures.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	PLAN EXISTS RESOURCE : POOR
98. Special administrative procedures for disasters Verify that the plan includes procedures for contracting personnel and for procurements in case of disaster. Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Plan exists, personnel have been trained, and resources are in place to carry out the procedures.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	RESOURCES ARE NOT ENOUGH. AVAILABILITY OF PERSONEL MIGHT TAKE SOME TIME DURING UNOFFICIAL HOURS.
99. Financial resources for emergencies are budgeted and guaranteed Verify that the hospital has a specific budget for use in disaster situations. Low = Not budgeted; Average = Funds will cover less than 72 hours; High = Funds are guaranteed for 72 hours or more.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	FUND OF 90,000 RUFYIYA - FOR EMERGENCY SITUATIONS. (NOT SPECIFIC TO DESASTERS)
100. Procedures for expanding usable space, including the availability of extra beds The plan identifies physical spaces that can be equipped to treat mass casualties. Low = Space for expansion has not been identified; Average = Space has been identified and personnel have been trained to carry out the expansion; High = Procedures exist, personnel have been trained, and resources are in place to carry out expansion of space.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	DURING TSUNAMI - THAJUDHEEN SCHOOL HALL WAS USED AS AN INPATIENTCARE AREA BUT AS FOR A PROTOCOL:THIS DOES NOT EXIST.
101. Procedures for admission to the emergency department The plan specifies the places and personnel responsible for carrying out triage. Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	EMERGENCY STOCK OF MEDICATIONS- NON EXISTANT.

102. Procedures to expand emergency department and other critical services The plan should indicate actions needed to expand hospital services (for example, drinking water supply, power, wastewater). Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
103. Procedures to protect patients' medical records The plan indicates how medical and other critical patient records can be safely moved. Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	INPATIENT AND OUT PATIENT RECORDS CANNOT BE EASILY TRACED.
104. Regular safety inspections are conducted by the appropriate authority Note the expiration and/or refill dates of fire extinguishers and of flow tests for fire hydrants. Examine logbooks that record equipment tests and dates of inspections by civil defence personnel. Low = Inspections do not occur; Average = Incomplete or outdated inspection; High = Inspections are complete and up-to-date.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
105. Procedures for hospital epidemiological surveillance Verify that the hospital's Epidemiological Surveillance Committee has specific procedures for disaster incidents or treatment of mass casualties. Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	COMITTEE EPIDEODEMIC SURVEILLANCE - EOC - IS INITIATED ONLY IN CASE OF DISASTER (ACTIVATED)
106. Procedures for preparing sites for temporary placement of dead bodies and for forensic medicine Verify that the plan includes specific arrangements for pathology and a site for the placement of multiple cadavers. Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
107. Procedures for triage, resuscitation, stabilization, and treatment Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
108. Transport and logistics support Confirm that the hospital has ambulances and other official vehicles. Low = Ambulances and vehicles for logistic support are not available; Average = There are insufficient vehicles; High = Appropriate vehicles in sufficient numbers are available.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	VEHICLES ARE INSUFFICIENT, MNDP / POLICE SERVICES / PUBLIC VEHICLES CAN BE USED BE USED OR MADE AVAILABLE.
109. Food rations for hospital staff during the emergency The plan specifies actions for supplying food during the emergency and funds for these supplies are included in the budget. Low = None/ntant; Average = Covers less than 72 hours; High = Guaranteed for at least 72 hours.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	NO PLAN SPECIFIED
110. Duties assigned for additional personnel mobilized during the emergency Low = Assignments do not exist or exist only in a document; Average = Duties are assigned and personnel have been trained; High = Duties are assigned, personnel have been trained, and resources are in place to mobilize the personnel.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

<p>111. Measures to ensure the well-being of additional personnel mobilized during the emergency The plan identifies where emergency personnel can rest, drink, and eat. Low = None exist; Average = Measures cover less than 72 hours; High = Measures are ensured for at least 72 hours.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<p>112. Cooperative arrangements with local emergency plan There are written arrangements regarding cooperation between the hospital and community authorities. Low = No arrangements exist; Average = Arrangements exist but are not operational; High = Arrangements exist and are operational.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<p>COOPERATION WITH THE FOLLOWING DEPARTMENTS :</p> <ul style="list-style-type: none"> * PORT HEALTH MEDICAL SERVICES * MALDIVES NATIONAL DEFENCE FORCE * CONCERNED AIRLINE (ISLAND AVIATION)
<p>113. Mechanism to prepare a census of admitted patients and those referred to other hospitals The plan has specific forms that facilitate the listing of patients during emergencies. Low = Mechanism does not exist or exists only as a document; Average = Mechanism exists and personnel have been trained; High = Mechanism exists, personnel have been trained, and resources are in place to carry out the census.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<p>114. System for referral and counter-referral of patients Low = System does not exist or exists only as a document; Average = System exists and personnel have been trained; High = System exists, personnel have been trained, and resources are in place to carry out the plan.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<p>115. Procedures for communicating with the public and media The hospital disaster plan specifies who is responsible for communicating with the public and media in case of disaster (generally the highest person in the chain of command at the time of the event). Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<p>TRAININGS ARE CARRIED OUT THROUGH YEARLY DRILLS.</p>
<p>116. Procedures for response during evening, weekend, and holiday shifts Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<p>117. Procedures for the evacuation of the facility Verify procedures to evacuate patients, visitors, and staff. Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<p>EVACUATION OF PATIENTS FROM HOSPITAL WAS PRACTICED ONCE. ONLY AS A FIREDRILL. PROTOCOL FOR COMPLETE EVACUATION OF THE HOSPITAL - NOT WRITTEN.</p>
<p>118. Emergency and other exit routes are accessible Verify that exit routes are clearly marked and free of obstacles. Low = Exit routes are not clearly marked and many are blocked; Average = Some exit routes are marked and most are clear of obstacles; High = All exit routes are clearly marked and free of obstacles.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<p>7 EXIT GATES - 3 OF THEM CLOSED AND LOCKED.</p>
<p>119. Simulation exercises and drills The plan is tested regularly through simulations and drills, which are evaluated and modified as appropriate. Low = Plans are not tested; Average = Plans are tested, but not each year; High = Plans are tested annually and updated according to the results of the exercises.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<p>AS SUCH ONLY PROTOCOL FOR AN AIRPORT EMERGENCY HAS BEEN WRITTEN DOWN.</p>

4.3 Contingency plans for medical treatment in disasters	Level of Implementation			OBSERVATIONS
	LOW	AVERAGE	HIGH	
<p>120. Earthquakes, tsunamis, volcanoes, and landslides IF THESE HAZARDS DO NOT EXIST WHERE THE HOSPITAL IS LOCATED, LEAVE THE BOXES BLANK. Low = Plan does not exist or exists only as a document; Average = Plan exists and personnel have been trained; High = Plan exists, personnel have been trained, and resources are in place to carry out the plan.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<p>* EXTRA-ORDINARY INCIDENTS - TSUNAMI 2004 * EARTHQUAKES - LOW INTENSITY MMI = V-VI * FOR MAJOR FIRE AND TSUNAMI- NOT PREPARED.</p>
<p>121. Social conflict and terrorism Low = Plan does not exist or exists only as a document; Average = Plan exists and personnel have been trained; High = Plan exists, personnel have been trained, and resources are in place to carry out the plan.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<p>122. Floods and hurricanes IF THESE HAZARDS DO NOT EXIST WHERE THE HOSPITAL IS LOCATED, LEAVE THE BOXES BLANK. Low = Plan does not exist or exists only as a document; Average = Plan exists and personnel have been trained; High = Plan exists, personnel have been trained, and resources are in place to carry out the plan.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<p>FLOODS * DUE TO RAIN / TIDAL WAVE. * BARRIER PROTECTION FOR TIDAL WAVES SINCE 2008. HOSPITAL IS 2M HEIGHT FROM SEA LEVEL. PLAN OF ACTION FOR SUCH AN INCIDENT DOES NOT EXIST.</p>
<p>123. Fires and explosions. Low = Plan does not exist or exists only as a document; Average = Plan exists and personnel have been trained; High = Plan exists, personnel have been trained, and resources are in place to carry out the plan.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<p>Lack of preparedness for fires within premises or fire events elsewhere requiring emergency response from hospital</p>
<p>124. Chemical accidents OR exposure to ionizing radiation Low = Plan does not exist or exists only as a document; Average = Plan exists and personnel have been trained; High = Plan exists, personnel have been trained, and resources are in place to carry out the plan.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<p>125. Pathogens with epidemic potential Low = Plan does not exist or exists only as a document; Average = Plan exists and personnel have been trained; High = Plan exists, personnel have been trained, and resources are in place to carry out the plan.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<p>126. Psycho-social treatment for patients, families, and health workers Low = Plan does not exist or exists only as a document; Average = Plan exists and personnel have been trained; High = Plan exists, personnel have been trained, and resources are in place to carry out the plan.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<p>AS PER PERSON - PLAN DOES NOT EXIST BUT EXPERIENCE SHOWS THAT, PSYCHO-SOCIAL FACTORS ARE TAKEN CARE OF, BY VARIOUS GROUPS IN THE TSUNAMI INCIDENT.</p>
<p>127. Control of hospital-acquired infections Request the corresponding hospital manual and verify whether control procedures are in force. Low = Manual does not exist or exists only as a document; Average = Manual exists and personnel have been trained; High = Manual exists, personnel have been trained, and resources are available to implement measures.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<p>See responses to questions in Section 1 in regard to Epidemics and Infections</p>

4.4 Plans for the operation, preventive maintenance, and restoration of critical services Measure the level of availability, accessibility, and relevance of documents that are essential when responding to an emergency.	Level of availability			OBSERVATIONS
	LOW	AVERAGE	HIGH	
128. Electric power supply and back-up generators The maintenance division should provide the operations manual for the back-up electric generator as well as preventive maintenance records. <i>Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
129. Drinking water supply The maintenance division should provide the operations manual for the water supply system as well as records on preventive maintenance and water quality control. <i>Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
130. Fuel reserves The maintenance division should provide the operations manual for fuel supplies, as well as preventive maintenance records. <i>Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
131. Medical gases The maintenance division should provide the operations manual for medical gases supply, as well as preventive maintenance records. <i>Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
132. Standard and back-up communications systems <i>Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
133. Wastewater systems The maintenance division should ensure that hospital wastewater drains into the public sewage system and does not contaminate drinking water. <i>Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	See responses to questions in Section 1 related to wastewater management system
134. Solid waste management The maintenance division should provide the operations manual for solid waste management, as well as records showing waste collection and subsequent disposal. <i>Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	See responses to questions in Section 1 related to solid waste management system

Risk Safety Assessment for Health Infrastructure in the Republic of Maldives, Jaime F. Argudo, Ph.D., P.E. – WHO Consultant

135. Maintenance of the fire protection system The maintenance division should provide the operations manual for the fire protection systems, as well as records showing preventive maintenance on fire extinguishers and fire hydrants. <i>Low = Procedures do not exist or exist only in a document; Average = Procedures exist and personnel have been trained; High = Procedures exist, personnel have been trained, and resources are in place to implement them.</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	CURRENTLY BEING EVALUATED, AND IN FUTURE PROTOCOL AND RESOURCES WILL BE PUT IN. FIRE HAZARD IS THE NUMBER ONE RISK IN HOSPITAL
4.5 Availability of medicines, supplies, instruments, and other equipment for use in emergency Verify the availability of essential supplies in the event of an emergency.	Level of availability			OBSERVATIONS
	LOW	AVERAGE	HIGH	
136. Medicines Check the availability of emergency medicines. The WHO list of essential drugs can be used as a reference. <i>Low = Nonexistent; Average = Supply covers less than 72 hours; High = Supply is guaranteed for at least 72 hours.</i>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	EXISTING STOCK OF THE HOSPITAL - PROVIDES MEDICATIONS FOR 4 MONTHS APPROXIMATELY. AND CAN BE MADE AVAILABLE IN LESS THAN 24 HOURS.
137. Items for treatment and other supplies Check that the sterilization unit has a supply of sterilized materials for use in an emergency (check the supply prepared for the following day). <i>Low = Nonexistent; Average = Supply covers less than 72 hours; High = Supply guaranteed for at least 72 hours.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
138. Instruments Verify the existence and maintenance of specific instruments used in emergencies. <i>Low = Nonexistent; Average = Supply covers less than 72 hours; High = Supply guaranteed for at least 72 hours.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
139. Medical gases Verify the phone numbers and addresses of medical gas supplier and ensure availability in an emergency from the supplier. <i>Low = Nonexistent; Average = Supply covers less than 72 hours; High = Supply guaranteed for at least 72 hours.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	AT PRESENT OUR SUPPLIES HAVE RUN DOWN - LAST 15 DAYS DUE TO FINANACIAL ISSUES. CURRENTLY ON A PROSPECT TO PROVIDE O2 OF OWN (5 DAYS STOCK - 150 LARGE CYLINDERS.)
140. Mechanical volume ventilators The Hospital Disaster Committee should provide documentation on quantity and conditions of use of this equipment. <i>Low = Nonexistent; Average = Supply covers less than 72 hours; High = Supply guaranteed for at least 72 hours.</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	* 9 VENTILADORES * 2 PORTABLE VENTILATORS ALMOST ALWAYS IN USE HULHUMALE HOPSITAL - 8 VENTILATORS (CAN BE MADE AVAILABLE)
141. Electro-medical equipment The Hospital Disaster Committee should provide documentation on quantity and conditions of use of this equipment. <i>Low = Nonexistent; Average = Supply covers less than 72 hours; High = Supply guaranteed for at least 72 hours.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
142. Life-support equipment <i>Low = Nonexistent; Average = Supply covers less than 72 hours; High = Supply guaranteed for at least 72 hours.</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
143. Personal protection equipment for epidemics (disposable) Verify the hospital's stocks of personal protection equipment for staff working in areas of initial contact and treatment. <i>Low = Nonexistent; Average = Supply covers less than 72 hours; High = Supply guaranteed for at least 72 hours.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	GLOVES AND MASK - 5 MONTHS DISSPOSABLE GOWNS - AND EYE WEAR - <72 HOURS

<p>144. Crash cart for cardiopulmonary arrest The Hospital Disaster Committee should provide documentation on quantity, conditions of use, and locations of crash carts for treatment of cardiopulmonary arrest. <i>Low = Nonexistent; Average = Supply covers less than 72 hours; High = Supply guaranteed for at least 72 hours.</i></p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<p>CRASH CART FOR CARDIO PULMANORY ARREST EXISTS IN ALL WARDS. MEDICATIONS AND INSTRUMENTS CHECKED SYSTEMETICALLY.</p>
<p>145. Triage tags and other supplies for managing mass casualties The emergency department distributes and uses triage tags in case of mass casualties. Evaluate the supply in terms of the maximum capacity of the hospital. <i>Low = Nonexistent; Average = Supply covers less than 72 hours; High = Supply guaranteed for at least 72 hours.</i></p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<p>ONLY A FEW TRIAGE TAGS AVAILABLE. CURRENTLY UNDER LOCK AND KEY.</p>

Comments on the results of Form 2, Module 4:

BLOOD BANK - 84 PNTS AVAILABLE (OF DIFFERENT BOOLD GROUPS)
 PROTOCOL FOR MAINTAINING BLOOD SUPPLY - NON EXISTING.....
 INSTRUMENTS FOR STORAGE - NOT AVAILABLE.....

FOR AN EMERGENCY - 3 PNTS AVAILABLE - LIST IN LAB - TO CALL DONERS.....

EXISTING PROTOCOL IS TO CALL THE LIST OF DONORS FOR BLOOD DONATION. BLOOD CAN BE MADE AVAILABLE IN 2 HOURS TIME.....

Name/signature of evaluator

**Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
 Jaime F. Argudo, Ph.D., P.E. – WHO Consultant**

The Safe Index Assessment will provide the technical background to:

- Identify prevailing safety risks on the built infrastructure, environment, personnel and general public
- Identify actions to reduce risks against natural and human-made hazards
- Develop guidelines and tools for Sustainable Development Planning of Health Infrastructure and Services
- Develop Health Care Infrastructure and Service Standards for the Republic of Maldives
- Prioritize future investments on Health Infrastructure and Services in the Republic of Maldives

**Risk Safety Assessment for Health Infrastructure in the Republic of Maldives,
 Jaime F. Argudo, Ph.D., P.E. – WHO Consultant**