

List of conditions for Proposed Photovoltaic Solar Farm at Petite Riviere by SPV Petite Riviere Ltd (Ref: ENV/DOE/EIA/1732)

1. Notwithstanding all the other permits and clearances from the relevant authorities, the following permits shall be obtained and a copy submitted to the Director of Environment:
 - i. Clearance from the Department of Civil Aviation.
 - ii. Land Conversion Permit from the Ministry of Agro Industry and Food Security.

All conditions attached therewith shall be scrupulously observed.

2. The installation of the overhead transmission line from the solar farm to the CEB-La Tour Koenig substation shall have the prior approval of the District Council of Black River.
3. The development shall be undertaken as per the mitigating measures stated in the EIA report and the additional information submitted unless as otherwise advised herein.
4. The Department of Environment shall be informed in writing of the date of commencement of works for monitoring purposes. A detailed programme of works shall be submitted to the Department of Environment prior to the start of works.
5. In accordance with section 18(2)(l) of the Environment Protection Act 2002, the proponent shall submit to the Director of Environment, an Environmental Monitoring Plan (EMP) for approval prior to start of works. No infrastructural works shall start prior to the approval of the EMP. The proponent shall thereafter submit reports on the implementation accordingly.
6. The Department of Environment shall be informed in writing of the date of completion of all works on site, with copy of the as-built layout plan, prior to the start of operation for monitoring purposes.
7. All necessary precautions shall be taken to the satisfaction of the Water Resources Unit so that the proposed development does not impact negatively on the ground water and surface water quality.
8. The proponent shall ensure that the natural landform of the proposed development site is preserved and all existing natural drainage system for surface runoff shall be maintained.
9. All drainage infrastructures shall be designed and constructed to the satisfaction of the Local Authority and National Development Unit.
10. Transformer oil and used oil shall be sent to registered oil recyclers.
11. All wastewater generated during the implementation phase shall be disposed of to the satisfaction of the Wastewater Management Authority.
12. The construction wastes and excavated materials shall be reused for backfilling.

13. Any damaged PV panel generated during operational phase or faulty photovoltaic panels shall be exported to the supplier for disposal.
14. All electric motors such as air compressors, generators, transformers and other noise generating equipment shall be housed in sound attenuating structures so that noise generated therefrom shall be within permissible limits as per EPA (Standard for Noise Regulations).
15. The development shall not give rise to any form of pollution or nuisance by way of noise, vibration, dust, odour, or otherwise during site preparation, construction or operation phase to the surrounding environment.
16. In case of any environmental nuisances arising from this development, this Ministry will take necessary action in accordance with the provisions of the Environment Protection Act.
17. Any proposed deviation shall be subject to an application to the Director of Environment. No deviation or part thereof shall be executed prior to the determination of the application by the Director.