

**LIST OF CONDITIONS - PROPOSED CONSTRUCTION OF TWO PIPELINES FOR BUNKERING OF GASOIL AND FUEL OIL BETWEEN QUAY 1 AND QUAY 5 AND THE STORAGE TANKS AT FORT GEORGE IN THE PORT LOUIS HARBOUR IN THE DISTRICT OF PORT LOUIS BY TOTAL (MAURITIUS) LTD AND VIVO ENERGY (MAURITIUS) LTD (ENV/DOE/EIA/1556)**

1. All other necessary permits/clearances from the relevant authorities including clearance from Mauritius Port Authority shall be obtained and all the conditions attached therewith shall be scrupulously observed. A copy of all the permits/ clearances obtained shall be submitted to the Director of Environment.
2. The development shall be undertaken as per the mitigating measures stated in the EIA report and additional information submitted unless as otherwise advised herein.
3. In accordance with section 18 2(1) of the Environment Protection Act 2002, the proponent shall submit to the Director of Environment, an Environmental Monitoring Plan (EMP) for approval prior to start of works. The proponent shall thereafter submit reports on the implementation, accordingly.
4. A contingency plan shall be set up to combat any case of accidental spillage. The contingency plan as provided for, under Section 30(3) (a) of the Environment Protection Act shall be submitted to the Director of Environment prior to operation.
5. The Department of Environment shall be informed in writing of the date of commencement of works. A detailed programme of work shall be submitted to the Department of Environment, Ministry of Environment & SD prior to the start of works.
6. Necessary measures shall be taken during the construction phase so as not to cause any nuisance by way of noise, vibration, dust and traffic to the neighbours, the surrounding environment and the public.
7. Necessary bunded walls shall be provided around tapping area to cater for any accidental spillage and leakage.

8. An automatic leak or malfunctioning detection system shall be incorporated into the piping system so as to cut off any fuel discharge from the pipeline.
9. A team of surveillance officers shall be placed at strategic points to monitor and check any accidental leakages during pumping operations.
10. Noise dampering barrier shall be provided for noise generating equipment and workers shall be provided with protective equipment. The noise level shall be within the permissible limits as per the Standards for Noise promulgated under the Environment Protection Act.
11. All domestic wastewater generated during construction phase shall be channeled to a retention tank and carted away to Wastewater Management Authority approved site by registered wastewater carriers.
12. Appropriate measures against fire hazards shall be taken to the satisfaction of the Government Fire Services. Necessary firefighting devices shall be made available at all times.
13. In case of any accidental bursting of the pipe and leakages, the proponent shall immediately cease all pumping operations through the pipe system and clean up and remove the spill at his own cost and to the satisfaction of the Department of Environment, Ministry of Environment & SD. In addition, the proponent shall be responsible for the damage caused by the spill to the environment.
14. The development shall not give rise to any form of nuisances to the public, neighbours and surrounding environment. In case of any environmental nuisances arising from this development, this Ministry will take necessary action in accordance with the provisions of the Environment Protection Act.
15. Any proposed deviation shall be subject to an application to the Director of Environment. No deviation or part thereof shall be executed prior to the determination of the application by the Director.