

**LIST OF CONDITIONS-VARIATION OF EIA LICENCE RE. PROPOSED
DESALINATION PLANT AT HILTON MAURITIUS & SPA AT WOLMAR
FLIC EN FLAC BY MORNING LIGHT CO. LTD [ENV/DOE/EIA/1553]**

- i) Necessary clearance being obtained from the Prime Minister's Office in view of the intake structure being proposed within public domain.
- ii) A detailed programme of work shall also be submitted to the Ministry of Fisheries prior to the start of works.
- iii) Appropriate identification buoys/structures shall be deployed around the intake structure in the lagoon to demarcate the suction point to the satisfaction of the Ministry of Fisheries and the Ministry of Tourism & leisure.
- iv) The promoter shall resolve any conflicts that may arise with fishermen and other users of the region.
- v) Public access to the sea and the beach shall be clear of any encumbrance and the public shall have free and unrestricted access thereto.
- vi) The proponent shall provide in consultation with the Water Resources Unit, a borehole upstream of the rejection tank to monitor the salinity of the ground water and any risk of seawater intrusion. *The analysis of the salinity of the ground water shall be undertaken on a weekly basis and the result submitted on a monthly basis to the Ministry of Environment & SD, Ministry of Fisheries and the Water Resources Unit of the Ministry of Energy and Public Utilities.*

The conditions of the EIA licence [ref: ENV/DOE/EIA/1553] dated 3 July 2012 remain in force.